

RESOLUTION

NO: [Title]

LIVINGSTON COUNTY

DATE: April 2, 2025

Resolution Authorizing the Capital Purchase of Fire System Equipment for the Historic Courthouse – Facility Services

WHEREAS, During a routine inspection at the Historic Courthouse the fire pump and control system was found to be in a state of disrepair and in need of emergent replacement, leaving the 136 year old building without fire suppression; and

WHEREAS, Facility Services coordinated with Howell Fire Department to determine that a 24/7 fire watch is necessary to safeguard the County’s assets until a new fire pump and control system can be installed; and

WHEREAS, Solomon Plumbing and Fire expedited a proposal to update and return the fire system back to working condition in the amount of \$67,100; and

WHEREAS, additional electrical and fire alarm work is necessary and estimated in the amount of \$3,000; and

WHEREAS, the equipment replacements in this proposal have been reviewed and approved by the Howell Fire Department and Livingston County Building Department; and

WHEREAS, this equipment was identified for replacement in 2027 in the 2024 Facility Services Facility Condition Assessment; and

WHEREAS, funding for this equipment replacement shall not exceed \$70,100 shall be paid from the Capital Replacement Fund; and

WHEREAS, expediting this replacement equipment is essential to protect one of Livingston County’s largest assets and to accrue less overtime costs by the Facility Services Department.

THEREFORE, BE IT RESOLVED that the Livingston County Board of Commissioners hereby authorizes the following:

- Purchase and installation of Historic Courthouse fire system equipment from Solomon Plumbing and Fire for a cost not to exceed \$70,100
- Creation of GL project code “CFCHR - Court House Fire System” in Fund 403
- Project be paid from Fund 403 Capital Replacement Fund

BE IT FURTHER RESOLVED that the Livingston County Board of Commissioners hereby authorizes any budget amendments necessary to effectuate the above.

#

#

#

MOVED:

SECONDED:

CARRIED: